

Supplement 2 to
EC-Type Examination Certificate No. FM06ATEX0018X
in accordance with Clause 6 of Annex III to Directive 94/9/EC.

Equipment or protective system:
(Type Reference and Name) **T950X-AabK I/P Converter**

Name of Applicant: **ControlAir Inc.**

Address of Applicant: **8 Columbia Drive
Amherst, NH 03031 USA**

The examination and test results are recorded in confidential report number 3028313EC supplement 2 dated 13th February 2009.

Description of the supplements and modifications:

13. **Description**

Addition of Natural Gas media option.

T950X-AabK I/P Converter

Energy Limitation Parameters

Ui = 30 Volts, li = 125 mA, Pi = 0.7 W, Ci = 1 nF, Li = 2.2 mH

a = Output Pressure: C, D, E

b = Options: A, B, T, or E



Andrew Was
Manager, FM Approvals Ltd.

Issue date: *13th February 2009.*

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE