

Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: **781 762 4300** F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

I/P Converter T900-AbAd

IS/I,II,III/1/CDEFG/T4 Ta = 70 °C- 431-990-023 Entity; Type 4X I/0/AEx ia/IIB/T4 Ta = 70 °C- 431-990-023 Entity; Type 4X

NI/I/2/ABCD; S/II,III/2/FG/T4 Ta = 70 °C; Type 4X

Entity Parameters: Ui (Vmax) = 30 V, Ii (Imax) = 125 mA, Pi = 0.70 W, Ci = 0 μF, Li = 0 mH

b = Output Pressure Range: C, D, E, F G, H, L, I, J

d = Options: A

Specific Conditions for use:

1. The enclosure contains aluminum and is considered to constitute a potential risk of ignition by impact or friction and must be taken into account during installation and use.

I/P Converter T900-AbDd

IS/I/1/CD/T4 Ta = 70 °C; - 431-990-023 Entity; Type 2 I/0/AEx ia/IIB/T4 Ta = 70 °C- 431-990-023 Entity; Type 2

NI/I/2/ABCD/T4 Ta = 70 °C; Type 2

Entity Parameters: Ui (Vmax) = 30 V, Ii (Imax) = 125 mA, Pi = 0.70 W, Ci = 0.030 μ F, Li = 0 mH

b = Output Pressure Range: C, D, E, F G, H, L, I, J

d = Options: A

Specific Conditions for use:

1. When installed in Division 2 Hazardous (classified) locations, a warning label must be prominently affixed near the unit(s) which warns that the cables must not be removed or inserted unless the area is known to be non-hazardous.

2. The enclosure contains aluminum and is considered to constitute a potential risk of ignition by impact or friction

and must be taken into account during installation and use.



I/P Converter T900-AbTd

IS/I/1/CD/T4 Ta = 70 °C; - 431-990-023 Entity; Type 2 I/0/AEx ia/IIB/T4 Ta = 70 °C- 431-990-023 Entity; Type 2

NI/I/2/ABCD/T4 Ta = 70 °C; Type 2

Entity Parameters: Ui (Vmax) = 30 V, Ii (Imax) = 125 mA, Pi = 0.70 W, Ci = 0.030 μF, Li = 0 mH

b = Output Pressure Range: C, D, E, F G, H, L, I, J

d = Options: A

Specific Conditions for use:

- 1. Must be installed in suitable equipment enclosure in accordance with ANSI/ISA S82.01 & S82.03.
- 2. When installed in Division 2 Hazardous (classified) locations, a warning label must be prominently affixed near the unit(s) which warns that the cables must not be removed or inserted unless the area is known to be non-hazardous.
- 3. The enclosure contains aluminum and is considered to constitute a potential risk of ignition by impact or friction and must be taken into account during installation and use.

E/P Converter T900-abAd

NI/I/2/ABCD; S/II,III/2/FG/T4 Ta = 70 °C; Type 4X

a = Input Signal Range: C, D, E, F

b = Output Pressure Range: C, D, E, F G, H, L, I, J

d = Options: A

E/P Converter T900-abcd

NI/I/2/ABCD/T4 Ta = 70 °C; Type 2 a = Input Signal Range: C, D, E, F

b = Output Pressure Range: C, D, E, F G, H, L, I, J

c = Electrical Connection: D, T

d = Options: A

Special Condition for use;

- 1. The E/P Converter type T900-AbcT, must be installed in suitable equipment enclosure in accordance with ANSI/ISA S82.01 & S82.03.
- 2. When installed in Division 2 Hazardous (classified) locations, a warning label must be prominently affixed near the unit(s) which warns that the cables must not be removed or inserted unless the area is known to be non-hazardous.

Equipment Ratings:

Intrinsically safe for Class I, II, and III, Division 1, Groups C, D, E, F, and G hazardous (classified) locations and intrinsically safe for Class I, Zone 0, Group IIB hazardous (classified) locations and suitable for Class I, II, and III, Division 2, Groups A, B, C, D, F, and G.

FM Approved for:

ControlAir Inc Amherst, NH



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3610	2010
Class 3611	2004
Class 3810	1995
ANSI/ISA 60079-0	2009
ANSI/ISA 60079-11	2009
ANSI/ISA NEMA 250	1991

Original Project ID: 3009267 Approval Granted: September 9, 2003

Subsequent Revision Reports / Date Approval Amended

Report Number Date Report Number Date

081119 January 29, 2010 3042023 March 6, 2012

FM Approvals LLC

J. E. Marquedant

Group Manager, Electrical

. E. Marquerdint

6 March 2012

Date